





**SMA  
SB7000US**



**Sub-panel**



**Meter/Main**




Point of Connection	
	Sub pane
Buss Rating	125
O.C. Rating	125
Available ampacity	25
Max Inverter Current	29

Non-compliant

Point of Connection	
	Meter
Buss Rating	200
O.C. Rating	200
Available ampacity	40
Max Inverter Current	29

Compliant



© 2007 Miller Power & Communications  
Duplication prohibited w/out written permission

<b>Miller Power &amp; Communications</b>		17395 Oak Rd. Atascadero, CA 93422 805-438-5600 Fax 438-4607	
License: 773985			
Client	Client		
Street	Street		
City, State Zip	City, State Zip		
Drawn by	Title		
Date	7/29/08	Sub-Title	Page-1
Revised	7/29/08	File	POC Example.vsd
		Page:	1 of 1